



## **What is the quantity of air required by a person in normal work environment ?**

ARI [ American Institute For Refrigeration Standards ] "Ventilation for Acceptable Indoor Air Quality" specifies the minimum and recommended fresh air quantities necessary to obtain acceptable indoor air quality for a variety of indoor spaces recommends an average fresh air intake of 20 CFM [Cubic Feet per Min per person].